U.S. Government

Federal law prohibits removal of this label before consumer purchase.

ENERGYGUIDE

Central Air Conditioner
Cooling Only
Split System

XYZ Corporation
Model HC47
Capacity 57,000 Btu/h

Efficiency Rating (SEER)*

13.0-14.2

13.0 Least Efficient — **24.5** Most Efficient

Range of Similar Models

* Seasonal Energy Efficiency Ratio

This system's efficiency rating depends on the coil your contractor installs with this unit. Ask for details.

For energy cost info, visit **productinfo.energy.gov**

Notice

The installed system must meet minimum federal regional efficiency standards.
See **productinfo.energy.gov** for certified coil combinations.

North AK, CO, CT, ID, IL, IA, IN, KS, ME, MI, MN, MO, MT, ND, NE, NH, NJ, NY, OH, OR, PA, RI, SD, UT, VT, WA, WV, WI, WY

Southeast AL, AR, DC, DE, FL, GA, HI, KY, LA, MD, MS, NC, OK, SC, TN, TX, VA, U.S. Territories

Southwest AZ, CA, NM, NV

Minimum Standards

	North	Southeast	Southwest
SEER	13	14	14
EER†			12.2
EER††			11.7

† Units with rated capacity of less than 45,000 btu/h
†† Units with rated capacity equal to or greater than 45,000 btu/h

Energy Efficiency Ratio (EER): could range from 11.4 to 12.5, depending on the coil installed with this unit

Sample Label 7A Split-system Central Air Conditioner (models manufactured after the compliance date of DOE regional efficiency standards in 10 CFR part 430)