

Table 1--Electrical Safety Requirements in §1910.269

Compliance with Subpart S Will Comply with These Paragraphs of §1910.269 ¹
(d), electric-shock hazards only
(h)(3)
(i)(2)
(k)
(l)(1) through (l)(4), (l)(6)(i), and (l)(8) through (l)(10)
(m)
(p)(4)
(s)(2)
(u)(1) and (u)(3) through (u)(5)
(v)(3) through (v)(5)
(w)(1) and (w)(7)

Paragraphs that Apply Regardless of Compliance with Subpart S ²
(a)(2) and (a)(3)
(b)
(c)
(d), for other than electric-shock hazards
(e)
(f)
(g)
(h)(1) and (h)(2)
(i)(3) and (i)(4)
(j)
(l)(5), (l)(6)(ii), (l)(6)(iii), (l)(7), and (l)(11)
(n)
(o)
(p)(1) through (p)(3)
(q)
(r)
(s)(1)
(t)
(u)(2) and (u)(6)
(v)(1), (v)(2), and (v)(6) through (v)(12)
(w)(2) through (w)(6), (w)(8), and (w)(9)

¹If the electrical installation meets the requirements of §§1910.302 through 1910.308 of this part, then the electrical installation and any associated electrical safety-related work practices conforming to §§1910.332 through 1910.335 of this part are considered to comply with these provisions of §1910.269 of this part.

²These provisions include electrical safety and other requirements that must be met regardless of compliance with Subpart S of this part.