

ENERGYGUIDE


Central Air Conditioner
Cooling Only
Split System

XYZ Corporation
Model HC47



Efficiency Rating (SEER)*

13.0-14.2



Range of Similar Models

* Seasonal Energy Efficiency Ratio

▼▼ This system's efficiency rating depends on the coil your contractor installs with this unit. Ask for details.

For energy cost info, visit productinfo.energy.gov

Notice

The installed system must meet minimum federal regional efficiency standards. See productinfo.energy.gov for certified coil combinations.



- North** □ AK, CO, CT, ID, IL, IA, IN, KS, MA, ME, MI, MN, MO, MT, ND, NE, NH, NJ, NY, OH, OR, PA, RI, SD, UT, VT, WA, WV, WI, WY, U.S. Territories
- Southeast** □ AL, AR, DC, DE, FL, GA, HI, KY, LA, MD, MS, NC, OK, SC, TN, TX, VA
- Southwest** ■ AZ, CA, NM, NV

Minimum Standards

	North	Southeast	Southwest
SEER	13	14	14
EER [†]			12.2
EER ^{††}			11.7

[†] Units with rated capacity of less than 45,000 btu/h
^{††} Units with rated capacity equal to or greater than 45,000 btu/h

Energy Efficiency Ratio (EER): could range from 11.4 to 12.5, depending on the coil installed with this unit