

Figure 3280.402(b)(1) – Test fixture for testing trusses singly

A single truss shall be positioned in the air cylinder or hydraulic test apparatus so that no more than the recommended bearing surface of the truss is supported. The truss shall be positioned so that the ends of the cylinder brackets (i.e., shoes) are the same distance (A) from both ends of the truss.

